



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx TUR 23.0052X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2023-11-17

Applicant: **NorthEx Zone Elektrik Sanayi Ve Dış Tica**
AKTİM 1 TİCARET ve İŞ MERKEZİ
Akçaburgaz Mahallesi Akçaburgaz Caddesi Numara 20
Bağımsız Bölüm 34
34522 Esenyurt
Türkiye

Equipment: **junction Box LJB1, LJB1S - *, LJB2, LJB2D, LJB2W**

Optional accessory:

Type of Protection: **Ex d, Ex t**

Marking: Ex db IIC T6, T5 or T4 Gb
Ex tb IIIC T85°C, T100°C or T135°C Db

Approved for issue on behalf of the IECEx
Certification Body:

Dipl. -Ing. Klauspeter Graffi

Position:

Head of Certification Body

Signature:
(for printed version)

Date:
(for printed version)

2023-11-17

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

TUV Rheinland Industrie Service GmbH
Am Grauen Stein
51105 Cologne
Germany





IECEx Certificate of Conformity

Certificate No.: **IECEx TUR 23.0052X**

Page 2 of 3

Date of issue: 2023-11-17

Issue No: 0

Manufacturer: **NorthEx Zone Elektrik Sanayi Ve Diř Tica**
AKTİM 1 TİCARET ve İř MERKEZİ
Akçaburgaz Mahallesi Akçaburgaz Caddesi Numara 20
Bağımsız Bölüm 34
34522 Esenyurt
Türkiye

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-1:2014](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

[IEC 60079-31:2013](#) Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/TUR/ExTR23.0052/00](#)

Quality Assessment Report:

[DE/TUR/QAR22.0005/00](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx TUR 23.0052X**

Page 3 of 3

Date of issue: 2023-11-17

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The LJB Junction Boxes are manufactured in two sizes, designated as Type LJB1 and LJB2 enclosures.

Both Types use an aluminium screw cover enclosure that is provided with internal and external earthing facilities and its walls have threaded entries that allow external cables to be connected. This enclosure is certified under IECEx TUR 23.0054U.

Internally, the LJB1 may be fitted with baseboard mounted terminals, the LJB2 may be fitted with baseboard mounted terminals, transformers, relays, contactors, electronic devices and fuses, as detailed on the scheduled drawings.

In addition following variants of LJB* series are available:

LJB1S - * contains a rotary switch (* = type of switch).

LJB2D consist of a dome shaped cover.

LJB2W consist of a cover with window.

The maximum permitted internal power dissipations (in Watts) for various temperature classes, are as follows:

Designation	T _a = -30°C to +55°C			T _a = -20°C to +40°C		
	T6	T5	T4	T6	T5	T4
LJB 1	10	18	39	18	26	47
LJB 2	15	28	57	28	41	70






SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The cable entry holes shall be fitted with suitably certified cable glands or suitably certified stopping plugs, which are capable of maintaining the IP66/67 rating of the equipment.
2. The flame proof joints are not intended to be repaired.
3. When these enclosures are incorporated as part of certified equipment, any internally mounted components must not exceed the bounds of the baseboard and must not exceed more than 60% of any internal cross-section.
4. Specific guidance noted to contact the original manufacturer for information on the dimension of the flameproof joints.
5. The device has to be protected against charging mechanisms such as fast-moving particles along a surface, pneumatic transfer of powders, and charge spraying in electrostatic coating processes in explosive dust atmospheres.

Annex:

[Attachment IECEx TUR 23.0052X.pdf](#)

The LJB1S - *, are available as follows:

Type	Contacts / poles		Ie / Ve	Entry arrangement	Entry size(s)
LJB1S - A	0 - 1		20A / 690v		<p>Entries shall be threaded with any combination of following thread forms/sizes:</p> <p>A. Standard: ISO M16 to M25 to BS 3643 pt2 1.5mm pitch (medium fit 6H)</p> <p>B. Alternative: 1/2 NPT to 3/4 NPT to ANSI/ASME B1.20.1, gauging flush to 2 turns large, with L1 plug gauge.</p> <p>Unused entries shall be plugged with a suitable "Ex d" certified stopping plugs.</p> <p>Max. number of entries = 4</p> <p>Max.</p>
LJB1S - B	1 - 2		20A / 690v		
LJB1S - C	1 - 0 - 2		20A / 690v		
LJB1S - D	0 - 1		20A / 690v		